

MONTH	JULY		JEFF GUNDERSON							
	Day of Month	HOLIDAY PTO	# of Hours: Streets, General Maint, Snow Removal, Sewer Line, Water Line	# of Hours: Water Plant	# of Hours: Sewer Plant	# of Hours: Parks, Mowing	# of Hours: Building Maint	# of Hours: Shop Equipment Maintenance	# Hours Training, Paperwork and Reports	Total Hours Per Day
1						8				8
2				4		4				8
3										0
4										0
5		8								8
6				6	2					8
7						4			4	8
8			4			4				8
9			2	2			4			8
10										0
11										0
12				2	2	4				8
13						6		2		8
14				4		4				8
15						4			4	8
16				2		6				8
17										0
18										0
19				2	2	4				8
20						4		4		8
21				4		4				8
22					4			4		8
23				2	4	2				8
24										0
25										0
26			2	2	4					8
27					4	4				8
28						8				8
29			4			4				8
30			2	2		4				8
31										0
<b>TOTAL</b>	<b>8</b>		<b>14</b>	<b>32</b>	<b>22</b>	<b>78</b>	<b>4</b>	<b>10</b>	<b>8</b>	<b>176</b>

Customer Name : CAROLS, MN

SERVICE AGREEMENT

ADDITIONAL PARTS/ATTENTION NEEDED

Date: 8/9/2021

Inspected By: MITCH

Station Name: MAIN LS

Contact Person: JEFF

Phone Number:

	Pump 1	Pump 2
Make	ABS/SULZER	ABS/SULZER
Model	XFP100C-CB1.4 PE35/4	XFP100C-CB1.4 PE35/4
Serial Number	300268131	300268129
Horse Power	4.7	4.7
RPM	1731	1731
Date Code	10-2019	10-2019
Impeller Code	.4	.4
Volts	230 248/246/248	230
Phase	3	3
FLA's	12.4	12.4
Discharge Size	4"	4"
Amp Draws	9.8/10.5/10.5	9.1/9.8/9.6
Meg	550	550
Impeller Condition	GOOD	GOOD
Wear Ring Condition	GOOD	GOOD
Oil Condition	GOOD	GOOD
Pump Cord Condition	GOOD	GOOD
Hour Meter Readings	10333.24	8637.1

Additional Comments:

Control Panel

Manufacturer: RHOMBUS

Model:

Start Relay:

S/N: 508719

HP Rating: ELECTRALEC

Start Capacitor:

Run Capacitor:

Phase Monitor: SSAC PTMU 11

Alternator: SQ D

Starter Manufacturer: SQ D

Starter Size: NEMA 1

Lightning Arrestor: SD D SPRAD70

Rating:

Overload Manufacturer: SQ D

Type: FIXED

Number: B25

Model: CA462

Leak Detection/Overtemp Relay:  Y /  N

Make: ABS/SULZER

Cellular Dialer: NO

Panel Heater: WATTLOW 100W STRIP

Floats  Transducer: X4

**Additional Pump Information**

Pump Chains – Condition: GOOD Length: 25' Material: SS  
Pump Clevis' – Condition: GOOD Size: 3/8 SS  
Pump Handle – Condition: OK Style: SS  
Flow(GPM): \_\_\_\_\_ Total Dynamic Head(TDH): \_\_\_\_\_

**Lift Station Information (For Relabs)**

Station Type:  Wetwell /  Drywell Valve Vault:  Yes /  No  
Access Hatch Condition: OK Dimensions: 32X48 SPLIT  
Safety Gate:  Yes /  No If no, Dimensions: \_\_\_\_\_  
Guide System Type: DUAL Guide Pipe Diameter: 2"  
Structure Depth: 22' Structure Diameter: 6'  
Piping Size: 4" Conduit:  Yes /  No Type/Size: \_\_\_\_\_  
Gate Valves: 4" Check Valves: 4"

Station Layout

